

## Subtype Monoblock A2W Heat Pump 7kw R290

Certificate Holder	Foshan Shunde Zealux Electrical Appliances Co., Ltd.
Address	No.2-8, No.9 Road, Science and Technology zone, Xingtan Industrial Park, Xingtan Town, Shunde District, Foshan City
ZIP	528325
City	Guangdong
Country	CN
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	Monoblock A2W Heat Pump 7kw R290
Registration number	011-1W0862
Heat Pump Type	Outdoor Air/Water
Refrigerant	R290
Mass of Refrigerant	0.8 kg
Certification Date	23.08.2024
Testing basis	HP KEYMARK certification scheme rules V14

## Model XAH07Csi9

Model name	XAH07Csi9
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.90 kW	7.00 kW
El input	1.50 kW	2.30 kW
COP	4.50	3.00

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	58 dB(A)	58 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	182 %	139 %
Prated	5.06 kW	4.79 kW
SCOP	4.63	3.54
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.46 kW	4.23 kW
COP Tj = -7°C	3.09	2.36
Cdh Tj = -7 °C	0.960	0.970
Pdh Tj = +2°C	2.76 kW	2.47 kW
COP Tj = +2°C	4.77	3.47
Cdh Tj = +2 °C	0.910	0.920
Pdh Tj = +7°C	3.17 kW	3.01 kW

COP Tj = +7°C	6.25	5.00
Cdh Tj = +7 °C	0.900	0.910
Pdh Tj = 12°C	3.28 kW	3.40 kW
COP Tj = 12°C	6.93	6.56
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	5.06 kW	4.79 kW
COP Tj = Tbiv	2.71	1.85
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.06 kW	4.79 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	1.85
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.970	0.980
WTOL	75 °C	75 °C
Poff	5 W	5 W
PTO	54 W	54 W
PSB	5 W	5 W
PCK	43 W	43 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2259 kWh	2793 kWh

## Model ALSAVO HEAT 07i9

Model name	ALSAVO HEAT 07i9
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.90 kW	7.00 kW
El input	1.50 kW	2.30 kW
COP	4.50	3.00

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	58 dB(A)	58 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	182 %	139 %
Prated	5.06 kW	4.79 kW
SCOP	4.63	3.54
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.46 kW	4.23 kW
COP Tj = -7°C	3.09	2.36
Cdh Tj = -7 °C	0.960	0.970
Pdh Tj = +2°C	2.76 kW	2.47 kW
COP Tj = +2°C	4.77	3.47
Cdh Tj = +2 °C	0.910	0.920
Pdh Tj = +7°C	3.17 kW	3.01 kW

COP Tj = +7°C	6.25	5.00
Cdh Tj = +7 °C	0.900	0.910
Pdh Tj = 12°C	3.28 kW	3.40 kW
COP Tj = 12°C	6.93	6.56
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	5.06 kW	4.79 kW
COP Tj = Tbiv	2.71	1.85
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.06 kW	4.79 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	1.85
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.970	0.980
WTOL	75 °C	75 °C
Poff	5 W	5 W
PTO	54 W	54 W
PSB	5 W	5 W
PCK	43 W	43 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2259 kWh	2793 kWh